

2016-17 Water Sampling Results

* Please Note that for purposes of compliance, any concentration greater than 15 micrograms/liter (as defined as greater than or equal to 15.5 micrgrams/liter) is considered to exceed the lead action level.

Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
300-1	N	50867-1	CEL	05679	1/16/2017	07:04	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
300-2	N	50867-2	CEL	05679	1/16/2017	7:05	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
300-3	N	50867-3	CEL	05679	1/16/2017	7:05	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
300-4	N	50867-4	CEL	05679	1/16/2017	7:08	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
300-5	N	50867-5	CEL	05679	1/16/2017	7:08	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
300-6	N	50867-6	CEL	05679	1/16/2017	7:09	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
300-7	N	50867-7	CEL	05679	1/16/2017	7:09	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
300-8	N	50867-8	CEL	05679	1/16/2017	7:11	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
300-9	N	50867-9	CEL	05679	1/16/2017	7:12	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
300-10	N	50867-10	CEL	05679	1/16/2017	7:13	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
300-11	N	50867-11	CEL	05679	1/16/2017	7:16	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
300-12	N	50867-12	CEL	05679	1/16/2017	7:16	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
300-13	N	50867-13	CEL	05679	1/16/2017	7:17	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
300-14	N	50867-14	CEL	05679	1/16/2017	7:19	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
300-15	N	50867-15	CEL	05679	1/16/2017	7:19	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
300-16	N	50867-16	CEL	05679	1/16/2017	7:21	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
300-17	N	50867-17	CEL	05679	1/16/2017	7:22	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
300-18	N	50867-18	CEL	05679	1/16/2017	7:23	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
300-19	N	50867-19	CEL	05679	1/16/2017	7:23	SM3113B	1/24/2017	9:15	10.8	2.00	1	N	
300-20	N	50867-20	CEL	05679	1/16/2017	7:24	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
300-21	N	50867-21	CEL	05679	1/16/2017	7:24	SM3113B	1/24/2017	9:15	5.18	2.00	1	N	
300-22	N	50867-22	CEL	05679	1/16/2017	7:25	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
300-23	N	50867-23	CEL	05679	1/16/2017	7:26	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
300-24	N	50867-24	CEL	05679	1/16/2017	7:26	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
300-25	N	50867-25	CEL	05679	1/16/2017	7:28	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
300-26	N	50867-26	CEL	05679	1/16/2017	7:29	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
200-1	N	50867-27	CEL	05679	1/16/2017	7:31	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
200-2	N	50867-28	CEL	05679	1/16/2017	7:31	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
200-3	N	50867-29	CEL	05679	1/16/2017	7:33	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
200-4	N	50867-30	CEL	05679	1/16/2017	7:33	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
200-5	N	50867-31	CEL	05679	1/16/2017	7:35	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
200-6	N	50867-32	CEL	05679	1/16/2017	7:35	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
200-7	N	50867-33	CEL	05679	1/16/2017	7:36	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
200-8	N	50867-34	CEL	05679	1/16/2017	7:36	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
200-9	N	50867-35	CEL	05679	1/16/2017	7:38	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
200-9A	N	50867-36	CEL	05679	1/16/2017	7:38	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
200-9B	N	50867-37	CEL	05679	1/16/2017	7:40	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
200-10	N	50867-38	CEL	05679	1/16/2017	7:42	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
200-10A	N	50867-39	CEL	05679	1/16/2017	7:42	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
200-10B	N	50867-40	CEL	05679	1/16/2017	7:43	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
200-11	N	50867-41	CEL	05679	1/16/2017	7:44	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
200-12	N	50867-42	CEL	05679	1/16/2017	7:44	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
200-13	N	50867-43	CEL	05679	1/16/2017	7:46	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
100-1	N	50867-44	CEL	05679	1/16/2017	7:48	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	

2016-17 Water Sampling Results

Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
100-2	N	50867-45	CEL	05679	1/16/2017	7:49	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
100-3	N	50867-46	CEL	05679	1/16/2017	7:49	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
100-4	N	50867-47	CEL	05679	1/16/2017	7:50	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
100-5	N	50867-48	CEL	05679	1/16/2017	7:50	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
100-6	N	50867-49	CEL	05679	1/16/2017	7:51	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
100-7	N	50867-50	CEL	05679	1/16/2017	7:52	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
100-8	N	50867-51	CEL	05679	1/16/2017	7:53	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
100-9	N	50867-52	CEL	05679	1/16/2017	7:56	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
100-10	N	50867-53	CEL	05679	1/16/2017	7:56	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
100-11	N	50867-54	CEL	05679	1/16/2017	7:57	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
100-12	N	50867-55	CEL	05679	1/16/2017	7:59	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
100-13	N	50867-56	CEL	05679	1/16/2017	7:59	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
100-14	N	50867-57	CEL	05679	1/16/2017	8:00	SM3113B	1/24/2017	9:15	4.34	2.00	1	N	
100-15	N	50867-58	CEL	05679	1/16/2017	8:02	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
100-16	N	50867-59	CEL	05679	1/16/2017	8:03	SM3113B	1/24/2017	9:15	<2.00	2.00	1	N	
100-17	N	50867-60	CEL	05679	1/16/2017	8:04	SM3113B	1/25/2017	15:00	<2.00	2.00	1	N	
100-18	N	50867-61	CEL	05679	1/16/2017	8:05	SM3113B	1/25/2017	15:00	<2.00	2.00	1	N	
100-19	N	50867-62	CEL	05679	1/16/2017	8:07	SM3113B	1/25/2017	15:00	<2.00	2.00	1	N	
100-20	N	50867-63	CEL	05679	1/16/2017	8:09	SM3113B	1/25/2017	15:00	<2.00	2.00	1	N	
100-21	N	50867-64	CEL	05679	1/16/2017	8:10	SM3113B	1/25/2017	15:00	<2.00	2.00	1	N	
100-22	N	50867-65	CEL	05679	1/16/2017	8:10	SM3113B	1/25/2017	15:00	<2.00	2.00	1	N	
SCIENCE WING-1	N	50867-66	CEL	05679	1/16/2017	8:13	SM3113B	1/25/2017	15:00	<2.00	2.00	1	N	
SCIENCE WING-2	N	50867-67	CEL	05679	1/16/2017	8:13	SM3113B	1/25/2017	15:00	<2.00	2.00	1	N	
GREEN HOUSE	N	50867-68	CEL	05679	1/16/2017	8:16	SM3113B	1/25/2017	15:00	<2.00	2.00	1	N	
MAINTENANCE GARAGE	N	50867-69	CEL	05679	1/16/2017	8:17	SM3113B	1/25/2017	15:00	<2.00	2.00	1	N	
ADMINISTRATION-1	N	50867-70	CEL	05679	1/16/2017	8:25	SM3113B	1/25/2017	15:00	<2.00	2.00	1	N	
ADMINISTRATION-2	N	50867-71	CEL	05679	1/16/2017	8:26	SM3113B	1/25/2017	15:00	<2.00	2.00	1	N	
TRIP BLANK	N	50867-72	CEL	5679	1/16/2017	6:30	SM3113B	1/25/2017	15:00	<2.00	2.00	1	N	